

ADDENDUMS AND CLARIFICATIONS

5/3/24

Please include this addendum with your bid packet.

- An Epoxy Grout must be used in both areas.
- On page 31, change Install 2'x2' tile on walls and benches in spa to 2"x2" tile on walls and benches in spa.
- Provide proper pitching of benches in steam room. They are currently perfectly level and water sits. We would like to add a little pitch for water to drain to the floor.